

Certificate of Compliance

Certificate: 70044987 **Master Contract: 246217**

Project: 70044987 **Date Issued:** 2016-01-08

Issued to: Pfannenberg, Inc.

86 Ward Road

Lancaster, New York 14086

USA

Attention: Joe Mazurkiewicz

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



William Kinas Issued by:

William Kinas

PRODUCTS

CLASS - C284101 - HEATERS-Industrial and Laboratory

CLASS - C284181 - HEATERS-Industrial and Laboratory - Certified to US Standards CLASS - C284181 - HEATERS-Industrial and Laboratory - Certified to US Standards

Industrial Air Heaters, component

	Rated	Frequency,	Heating	Dimensions
Model	Voltage	Hz	Performance (W)	(H x W x D)
PFH 200			200	
PFH 300			300	
PFH 400			400	
PFH 500	115 or 230	50/60	500	142 x 88 x
PFH 650			650	133mm
PFH 800			800	
PFH 1000			1000	
PFH 1200	230		1200	
Surrounding Air Temperature 40°C				

PFH optionally followed by T, describes Air Heater provided with thermostat controller -20 to 40°C

DQD 507 Rev. 2012-05-22



 Certificate:
 70044987
 Master Contract:
 246217

 Project:
 70044987
 Date Issued:
 2016-01-08

Notes:

This equipment is certified as a component for use in other equipment, where the suitability is determined in the end use by CSA. Some of the features which should be considered in determining the acceptability of this heater in the specific applications are indicated below:

- 1) The heater is intended for use within an enclosure in accordance with UL 508A, the standard for Industrial Control Panels.
- 2) The terminal block for the supply connections has not been evaluated for field wiring. It is suitable for 16-12 AWG.
- 3) Based on installation, the need for additional housing, guards (or the like) or (cautionary) marking shall be evaluated in the end-use.
- 4) The suitable mounting of the product shall be evaluated in the end use.
- 5) Grounding needs to be provided in the end-use.
- 6) The suitability of the fan is evaluated for max 40°C ambient. If used in a panel above 40°C consideration to environmental conditioning should be given.

APPLICABLE REQUIREMENTS

C22.2 No. 88-1958 (R2013) - Construction and Test of Industrial Heating Equipment UL 499 14th Edition – Electric Heating Appliances

DQD 507 Rev. 2012-05-22 Page 2



Supplement to Certificate of Compliance

Certificate: 70044987 Master Contract: 246217

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70044987	2016-01-08	Original Certification of Industrial Air Heater Models PFH 200, PFH 300, PFH 400, PFH 500, PFH 650, PFH 800, PFH 1000, and PFH 1200, with PFH optionally followed by T.

DQD 507 Rev. 2012-05-22 Page 1